







Model Code Modifications by Edition and Requirement

Requirement # Search term: "2.27.2"

This CodeFinder database report was generated for **[YOUR NAME]** and printed on **mm/dd/yyyy**. **[YOUR NAME]** is granted a single user non-transferable license for the use of CodeFinder database generated reports which are not to be copied in whole or in part for distribution outside **[YOUR COMPANY]**.

This icon  may appear at selected locations within the report. If an issue arises you are encouraged to click on the icon at the point of the issue and a feedback form will be generated. Please fill in the appropriate information and click on the submit feedback button.

 If this icon appears below that item's accuracy is being verified and is under review.

State: Wisconsin		Jurisdiction: State of Wisconsin		Code Type: Elevator New	
Agency Name					
Department of Commerce – Safety and Buildings Division – Elevator Systems Program					
Code: ASME A17.1/CSA B44 		Edition: 2007		Effective Date: 01/01/2009	
As of Date: Contract Award Date					
Comments:					
Requirement #	Comments	Effective Date	Document Link		
2.27.2 	Modified	07/01/2009			

Comm 18.1702(9)(a)

Emergency or Standby Power System

Where an emergency or standby power system is provided to operate an elevator in the event of normal power supply failure, the requirements of 2.27.2.1 through 2.27.2.5 shall be complied with.

Note: Standby power requirements for elevators in healthcare facilities are found in the National Electrical Code, Article 517 as adopted under ch. Comm 16. In other types of buildings standby power requirements are found in the building code under IBC chapter 62.